

**Proposed Rule Change List  
August 29, 2013**

NUMBER	SECTION	CHAPTER	PAGE	Paragraph	ITEM	PROPOSED CORRECTION
1	1	ALL			Delete section 1 in its entirety	Add to website
2	2	6	6000-1	Introduction	Strike "note" in first paragraph last sentence	Delete sentence
3	2	6	6101-1 thru 6324-10	All templates	Strike all quantities and "each" where appropriate in note section through out chapter 6 - example quantity of (4)	Delete all quantities - quantities are listed in standards
4	2	6	6101-1 thru 6324-10	Template footers	Strike and change dates at bottom	Change date to current date from 9/30/04
5	2	6	6101-2	Notes	Line 1. strike "wall mounted" & "floor drain"	Requirements are in standards
6	2	6	6101-4	Notes	Line 1. strike "wall mounted" & "floor drain"	Requirements are in standards
7	2	6	6101-7	Notes	Line 1. strike "wall mounted" & "floor drain"	Requirements are in standards
8	2	6	6103-10	Notes	Line 1. strike "wall mounted" & "floor drain"	Requirements are in standards
9	2	6	6103-17	Notes	Line 1. strike "wall mounted" & "floor drain"	Requirements are in standards
10	2	6	6107-1	Notes	Line 1. strike "single level switching"	Requirements are in standards
11	2	6	6109-1	Top left notes	Strike Percentages - 25%, 35%, 25%, 10% & 5%	Requirements are in standards
12	2	6	6109-2	Top left notes & note on right top side	Strike Percentages - 25%, 35%, 25%, 10% & 5%. Also, strike note "the sizing of the kitchen area assumes....." in its entirety.	Requirements are in standards
13	2	6	6109-9	Notes	Line 1. strike "wall mounted" and "floor drain"	Requirements are in standards
14	2	6	6111-1	Notes	Line 1. strike "wall mounted"	Requirements are in standards
15	2	6	6201-4	Notes	Line 1. strike "wall mounted" & "floor drain"	Requirements are in standards
16	2	6	6202-3	Notes	Line 1. strike "wall mounted"	Requirements are in standards
17	2	6	6203-10	Notes	Line 1. strike "wall mounted" & "floor drain".	Requirements are in standards
18	2	6	6203-17	Notes	Line 1. strike "wall mounted" & "floor drain".	Requirements are in standards
19	2	6	6209-3	Notes	Line 1. strike "wall mounted"	Requirements are in standards
20	2	6	6209-5	Notes	Line 2. strike "wall mounted"	Requirements are in standards
21	2	6	6211-1	Top left notes	Strike Percentages - 25%, 35%, 25%, 10% & 5%	Requirements are in standards
22	2	6	6211-2	Top left notes & note on right top side	Strike Percentages - 25%, 35%, 25%, 10% & 5%. Also, strike note "the sizing of the kitchen area assumes....." in its entirety.	Requirements are in standards
23	2	6	6211-9	Notes	Line 1. strike "wall mounted" & "floor drain".	Requirements are in standards
24	2	6	6213-1	Notes	Line 1. strike "wall mounted"	Requirements are in standards
25	2	6	6213-2	Notes	Line 2. strike "or" and replace with "and"	Requirements are in standards
26	2	6	6301-7	Notes	Line 1. strike "wall mounted" & "floor drain".	Requirements are in standards
27	2	6	6302-3	Notes	Line 1. strike "wall mounted"	Requirements are in standards
28	2	6	6303-10	Notes	Line 1. strike "wall mounted" & "floor drain".	Requirements are in standards
29	2	6	6303-19	Notes	Line 1. strike "wall mounted" & "floor drain".	Requirements are in standards
30	2	6	6306-14	Notes	Line 1. strike "wall mounted" & "floor drain".	Requirements are in standards
31	2	6	6307-4	Notes	Line 1. strike "wall mounted"	Requirements are in standards
32	2	6	6307-7	Notes	Line 1. strike "wall mounted"	Requirements are in standards
33	2	6	6310-1	Top Left Notes	Strike Percentages - 25%, 35%, 25%, 10% & 5%	Requirements are in standards
34	2	6	6310-2	Top left notes & note on right top side	Strike Percentages - 25%, 35%, 25%, 10% & 5%. Also, strike note "the sizing of the kitchen area assumes....." in its entirety.	Requirements are in standards
35	2	6	6310-9	Notes	Line 1. strike "wall mounted" & "floor drain".	Requirements are in standards
36	2	6	6312-1	Notes	Line 1. strike "wall mounted"	Requirements are in standards
37	2	6	6312-2	Notes	Line 2. strike "or" and replace with "and"	Requirements are in standards
38	2	6	6313-12	Notes	Line 2. strike "wall mounted"	Requirements are in standards
39	2	6	6315-17	Notes	Line 1. strike "wall mounted" & "floor drain".	Requirements are in standards
40	2	6	4101-8		Strike page in entirety	Page should not be in manual
41	2	6	6324-1	Notes	Line 1. strike "wall mounted"	Requirements are in standards
42	2	6	6324-2	Notes	Line 2. strike "or" and replace with "and"	Requirements are in standards
43	2	8			Delete in its entirety	Shown on website
44	2	1	1000-2	1st Paragraph	Strike "eight" and replace with "seven"	Striking chapter eight
45	2	1	1000-2	List of chapters	Strike "Chapter 8: Cost Guidelines"	Striking chapter 8 - Cost factors on website
46	2	1	1000-3		Strike all of chapter 8 reference	Striking chapter 8 - Cost factors on website
47	2	1	1100-2	5C	Strike paragraph "C"	SF is required by standard

**Proposed Rule Change List  
August 29, 2013**

NUMBER	SECTION	CHAPTER	PAGE	Paragraph	ITEM	PROPOSED CORRECTION
48	2	1	1100-2	5	Strike statement "b." in notes.	SF is required by standard
49	2	1	1100-3	B	Strike "Deviations from the site size recommendations must be approved by the Arkansas Department of Education"	Site size is district's responsibility.
50	2	1	1100-3	2nd note	Strike "variances will be considered by the Department of Education"	Site size is district's responsibility.
51	2	1	1100-5	Openings	unbold "A." and "B."	Guidelines - not standards
52	2	1	1100-5	Plumbing	Bold line "A."	Standard
53	2	1	1100-6	Electrical	Bold line "B."	Standard
54	2	1	1100-6	Electrical	Strike line "A."	Clarification in standards
55	2	1	1100-6	Electrical	Strike "and feeder circuits" from sentence	Clarification in standards
56	2	1	1200-1	B	Strike sentence "as defined in Section 1 of the .... Department of Education"	Section 1 deleted
57	2	1	1300-1	Distance Learning	Add "a" before "nd"	Correct spelling
58	2	3	3000-2	A	Change 7-8 to 6-8	WD required at 6th grade.
59	2	7	7000-1	Definitions	Add "in bold" after word "standards"	Standards are in bold
60	2	7	7100-1	Standards	Add #13 - Perimeter insulation at foundation to shall be 1" rigid board at minimum.	Add insulation standard
61	2		TOC -10	7130-7	Strike "coal tar roof system"	Delete system
62	2	5	POR	5600-4	E-AC-9 support space change suggested SF to 850	SF below 850 SF
63	2	5	POR	5600-4	M-AC-7 support space change suggested SF to 850	SF below 850 SF
64	2	5	POR	5600-1	Change E-AC-4 Kindergarten restroom to 45 SF	Reduce size of restroom
65	2	5	POR	5600-1	Add "H" to media center computer lab	Add high school to requirement
66						
67	2	5	POR	5600-1	Add GT classroom to required space. E-GT-1	Add note to space notes 5600-12. E-GT-1
68	2	5	POR	5600-7	Add drama room to support space in performing arts. H-PA-14 List at 850 SF	Add drama room
69	2	5	POR	5600-8,9,10,11	Change size from "suggested" to "required"	Requested by Career Development
70	2	5	POR	5600-12	Limit minimum size of single PE space to 900 SF. E-PE-1, M-PE-1, H-PE-1	Add to space notes E-PE-1, M-PE-1, H-PE-1
71	2	5	POR	5600-9	WD-AG-1 Agribusiness Lab increase SF From 1200 SF to 1500 SF	Requested by Career Education
72	2	5	POR	5600-10	Add WD-FCS-19 Consumer Services Lab at 1500 SF	Requested by Career Education
73	2	5	POR	5600-10	Add "Required Spaces in Cosmetology Lab - included in required SF".	Requested by Career Education
74	2	5	POR	5600-10	Add cosmetology space - WD-FCS-20 Restroom 100SF	Requested by Career Education
75	2	5	POR	5600-10	Add - Cosmetology space WD-FCS-21 Reception 250 SF	Requested by Career Education
76	2	5	POR	5600-10	Add - Cosmetology space WD-FCS-22 Supply 200 SF	Requested by Career Education
77	2	5	POR	5600-10	Add - Cosmetology space WD-FCS-23 Dispensary 150 SF	Requested by Career Education
78	2	5	POR	5600-10	Add - Cosmetology space WD-FCS-16 Office 120 SF to line below "required Spaces in Cosmetology Lab"	Requested by Career Education
79	2	5	POR	5600-10	Strike WD-FCS-16 Office 120 SF from "related Spaces and move to "Required Spaces in Cosmetology Lab"	Requested by Career Education
80	2	5	POR	5600-10	WD-AV-1 Advertising Design Lab Increase size from 800 SF to 1500 SF	Requested by Career Education
81	2	5	POR	5600-10	WD-AV-2 Career Communications Lab Increase size from 900 SF to 1500 SF	Requested by Career Education
82	2	5	POR	5600-11	Strike WD-AV-5 Photography Darkroom 150 SF	Requested by Career Education
83	2	5	POR	5600-11	WD-AV-10 Radio/TV Broadcasting Lab Increase size from 800 SF to 1200 SF	Requested by Career Education
84	2	5	POR	5600-12	WD-MAN-7 Related Spaces Classroom Increase size from 750 SF to 850 SF	Requested by Career Education
85	2	5	POR	5600-12	WD-ENG-2 Computer Engineering Lab Increase size from 1200 SF to 1500 SF	Requested by Career Education
86	2	5	POR	5600-12	WD-ENG-3 Geospatial Technology (GIS) Lab Increase size from 1200 SF to 1500 SF	Requested by Career Education

**Proposed Rule Change List  
August 29, 2013**

NUMBER	SECTION	CHAPTER	PAGE	Paragraph	ITEM	PROPOSED CORRECTION
87	2	5	POR	5600-12	WD-ENG-5 Related Spaces Classroom Increase size from 750 SF to 850 SF	Requested by Career Education
88	2	5	POR	5600-12	WD-TDL-7 Related spaces Classroom increase size from 750 SF to 850 SF	Requested by Career Education
89	2	7	7120-2	Components	Bold components 1-5	Make components standards
90	2	7	7120-2	Standards	#10 - strike the word "integral"	Exterior water repellant is available
91	2	7	7120-2	Guideline	#2 - strike "with integral color"	Exterior colors are available
92	2	7	7120-3	Components	Bold components 1-6	Make components standards
93	2	7	7120-3	Standards	#6 - Strike the word "integral" both places	Integral not required
94	2	7	7120-3	Standards	#8 - Strike "22" and add "20" in its place	Stronger stud
95	2	7	7120-5	Components	Bold components 1-7	Make standards
96	2	7	7120-5	Standards	#1 - Strike "0.0269 inches" and replace with "26 gauge"	Clarify thickness
97	2	7	7120-5	Standards	#7 - Strike "Type X". Add period after "wallboard". Add new statement "Type X where required by code"	Type X is not required every where.
98	2	7	7120-6	Components	Bold components 1-6	Make standards
99	2	7	7120-6	Standards	#6 - Strike the word "integral" both places	Integral not required
100	2	7	7130-1	Examples	#7 - strike 'cold tar roof system'	No longer accepted roofing system
101	2	7	7130		Add single-ply membrane back into manual	Deleted from last revision by mistake
102	2	7	7130-2, 3,4,5,6	Components	Bold all components	Make standards
103	2	7	7130-2	components	Strike "vented nailboard insulation"	Not required
104	2	7	7130-2	Construction standards	Add "7. 20 year minimum warranty on shingles and 2 year contractor's warranty.	Clarifies warranty period.
105	2	7	7130-2	Construction standards	End of Standard #5 Add - Continuous layer of ice and water sheild is acceptable alternative.	Ice and water sheild is better product
106	2	7	7130-3	Construction standards	Add #6. Roof panels minimum 26 gauge"	Clarifies roof panel thickness
107	2	7	7130-4	Construction standards	Add #6. Roof panels minimum 26 gauge"	Clarifies roof panel thickness
108	2	7	7140-2	Construction standards	#8 Strike word "wood" add word "wood" back in after solid -core	Requires interior doors to be wood.
109	2	7	7150-3	Construction standards	#4 - strike the word "type X"	Not all wallboard is type X
110	2	7	7150-3	Construction standards	Add - 11. Impact resistant materials in high traffic areas.	In performance guidelines - make standard
111	2	7	7190-3	Standards	#7 - strike "(5)" and replace with "(1)"	Reduces warranty
112	2	7	7200-3	Potable water system standards	#6 - strike "to minimum requirements of current energy code" and replace with "using fiberglass insulation"	Clarifies insulation requirement
113	2	7	7200-6	Standards	#13 - Strike "50" and replace with "100"	In line with plumbing code
114	2	7	7200-6	Standards	#16 - begin sentence with "district has option to"	Makes hose bibb optional for district choice.
115	2	7	7300-3	Temperature control systems	# A - close space after "advise the school district of"	Corrects typo
116	2	7	7300-3	Temperature control systems	# A - last sentence - strike "electronic night set back" and add "7 day programmable"	Clarifies thermostat requirement.
117	2	7	7300-4	Interior and exterior noise control guidelines	Strike "guidelines" and make total section A-D standards	Instructural spaces need to be ducted for noise and comfort control. This change was the intent of the last manual revision.
118	2	7	7400-2	Electrical distribution standards	#M - second sentence - add word "device" after first word "no" to read "no device conduits....."	Prevents conduit in slab to receptacles and switches.
119	2	7	7400-2	Electrical distribution standards	#M - after second sentence - add sentence "underground conduits may be used for feeders between MDP and secondary panels."	Allows the use of underground conduit to secondary panels which is more in line with industry standards.
120	2	7	7400-2	Electrical distribution standards	#M - Add the word "only" after the word "may" in the 4th sentence. To read "MC cable may only be used ...."	Prevents MC cable from being used in walls.

**Proposed Rule Change List  
August 29, 2013**

NUMBER	SECTION	CHAPTER	PAGE	Paragraph	ITEM	PROPOSED CORRECTION
121	2	7	7400-2	Electrical distribution standards	Add to section - O. MC cable not allowed for use in walls.	Strengthens above statement.
122	2	7	7400-3	Lighting standards	#G - Discuss whether "theatrical type lighting is required in student dining.	Dimmers may all that is necessary. Theatrical lighting may be optional.
123	2	7	7400-5	Fire Alarm Systems Standards	Strike standards A-L	Recommended by State Fire Marshal's office
124	2	7	7400-5	Fire Alarm Systems Standards	Insert new standard "A. Fire alarm and fire protection systems shall be installed per the Fire Prevention Code and NFPA 72.	Recommended by State Fire Marshal's office
125	2	7	7400-5	Fire Alarm Systems Standards	Insert new standard "B. Companies designing, installing or servicing fire alarm systems in Group E occupancies must be properly licensed by the Arkansas Board of Private Investigators, Private Security Agencies and Alarm Systems Companies.	Recommended by State Fire Marshal's office
126	2	7	7400-5	Fire Alarm Systems Standards	Insert new standard "C. Fire alarm shop drawings must be prepared in accordance with the Arkansas Fire Prevention Code and approved by the State Fire Marshal's Office or their Designee prior to installation.	Recommended by State Fire Marshal's office
127	2	7	7500-2	Wiring Standards	2.a. 2nd sentence strike "six" and replace with "ten"	Increase fiber requirement for increased bandwidth
128	2	7	7500-3	Telecom room wiring standard	1. Strike 1st and 2nd sentence in entirety	Stated twice in same paragraph and contradict each other.
129	2	7	7500-4	Building Wiring Guidelines	1. a. 1st sentence strike "two" and replace with "four"	Matches one outlet per wall per the 2nd sentence
130	2	7	7500-5	Building Wiring Guidelines	D. 1. 2nd sentence strike "six" and replace with "ten"	Increase fiber requirement for increased bandwidth
131	2	7	7500-5	Building Wiring Guidelines	D. 1. 3rd sentence strike "100 Mbps" and replace with "1 Gbps"	Increase requirement for increased bandwidth
<b>RULES CHANGES</b>						
	Partnership Program Rules	3.05	3	Paragraph 1	After "Appendix" strike "B" and replace with "A"	Corrects appendix reference
	Partnership Program Rules	3.05	3	Paragraph 1	In last sentence strike "com" and add "arkansas.gov"	Correct website
	Partnership Program Rules	3.06	3	Paragraph 1	In second sentence strike "3" in Sections 3.23 and insert Section 3.25 and strike "1" in 3.31 and replace with 3.33	Clarifies sections associated with state financial participation
	Partnership Program Rules	3.07.3	3	Paragraph 1	Strike the word "may" and replace with "shall"	Requires division to compute building value for each addition
	Partnership Program Rules	3.23	6	Paragraph 1	After "Appendix" strike "C" and replace with "B"	Corrects appendix reference
	Partnership Program Rules	3.23	6	Paragraph 1	Add "The District shall submit PORs for any new construction project that is not a warm, safe and dry systems project for the Division's review in accordance with Section 3.34 of these rules."	Requires ditrict to submit POR's
	Partnership Program Rules	3.25	8	(iii)	Add paragraph (iii) "In calculating the amount of state financial participation in a facilities project that includes a tornado shelter or designated reinforced area, the Division shall deduct from the project cost the total amount of grant funds received by the school district for the shelter or area."	Clarifies state financial participation calculations for facilities with tornado shelters
	Partnership Program Rules	3.28	9	Paragraph 1	Add "(systems)" after "warm, safe and dry" in first sentence	Clarifies type of project

**Proposed Rule Change List  
August 29, 2013**

NUMBER	SECTION	CHAPTER	PAGE	Paragraph	ITEM	PROPOSED CORRECTION
	Partnership Program Rules	3.28	9	Paragraph 1	Add "per Section 3.36.1 of these rules or addressing all building systems per Section 3.36.2 of these rules" after "facility system" in the first sentence.	Clarifies rule sections
	Partnership Program Rules	3.28	9	Paragraph 1	Add "system or space replacement" after "warm, safe and dry" in second sentence	Clarifies project type
	Partnership Program Rules	3.30	9	Paragraph 1	Strike "and meets any additional requirements set fourth in Section 7.02(i) of these Rules."	Schematic requirements will be listed in this section and removed from 7.02(i)
	Partnership Program Rules	3.30	9	Paragraph 1	Strike the second sentence "The schematic drawing does not have to be prepared ..... actual detail required."	Moved to 3.30.1
	Partnership Program Rules	3.30	9	3rd sentence	Strike the word "should" and replace with word "shall"	Clarifies schematic requirements
	Partnership Program Rules	3.30	9	3rd sentence	After "single line drawings with" add the word "outside" to dimensions	Clarifies schematic requirements
	Partnership Program Rules	3.30	9	3rd sentence	After word "dimensions," add "and overall gross square footage,"	Clarifies schematic requirements
	Partnership Program Rules	3.30	9	4th sentence	Add "For add-on or conversion projects the drawing shall be"	Clarifies schematic requirement
	Partnership Program Rules	3.30	9	4th sentence	After "labeled to identify all" add the word "interior"	Clarifies schematic requirements
	Partnership Program Rules	3.30	9	4th sentence	After the word "spaces" add "with interior room net square footage"	Clarifies schematic requirement
	Partnership Program Rules	3.30	9	5th sentence	After "warm, safe and dry" add "(systems)"	Clarifies what type of project
	Partnership Program Rules	3.30	9	5th sentence	After "their location" strike "should" and add "shall"	Makes major system components required
	Partnership Program Rules	3.30.1	9	New Paragraph 3.30.1	Add paragraph "The schematic drawing does not have to be prepared by a architect, but must meet the approval of the Division as to the actual detail required." to new paragraph 3.30.1	Moves this sentence from first paragraph
	Partnership Program Rules	3.30.2	9	New Paragraph 3.30.2	Add new paragraph "An aerial photograph is not a "diagram" and may not serve as the basis for the required schematic drawing."	Clarifies schematic requirement
	Partnership Program Rules	3.34	10	Paragraph 1	In second sentence change "Section 3.23 to 3.25. Strike the 3 and change to 5	Clarifies rule sections
	Partnership Program Rules	3.34	10	Paragraph 1	In third sentence add the word "(systems)" after "approved warm, safe and dry"	Clarifies type of project
	Partnership Program Rules	3.34.1	10	Paragraph 1	In the 1st sentence after "with existing educational facilities," insert sentence "the District shall submit a POR of the existing campus and"	Clarifies that the district submits POR with the project application
	Partnership Program Rules	3.34.1	10	Paragraph 1	In the second sentence after the words "school campus" add "(based on the Division's campus reports or other confirmed information made available to the Division)"	Clarifies information used in evaluation process
	Partnership Program Rules	3.34.1	10	Paragraph 1	After the second sentence add a new sentence "The District shall submit PORs for all campuses and grades affected by the grade reconfigurations which are a part of the project."	Clarifies PORs that districts need to be submit with project application

**Proposed Rule Change List  
August 29, 2013**

NUMBER	SECTION	CHAPTER	PAGE	Paragraph	ITEM	PROPOSED CORRECTION
	Partnership Program Rules	3.34.1	10	Paragraph 1	In the fourth sentence after "areas existing in school districts" add "on or before 2008"	This clarifies time of allowing consideration of single purpose spaces
	Partnership Program Rules	3.34.1	10	Paragraph 1	In the last sentence after "following four areas" add "that existed on or before 2008"	This clarifies time of allowing consideration of single purpose spaces
	Partnership Program Rules	3.34.2	10	Paragraph 1	In the 1st sentence after "the new academic facility," insert the sentence "the District shall submit a POR for the new school campus and"	Clarifies that the district submits POR with the project application
	Partnership Program Rules	3.34.2	11	Paragraph 1	In the first sentence after "square footage available in the district" insert "(based on the Division's campus and district reports or other confirmed information made available to the Division)"	Clarifies evaluation information
	Partnership Program Rules	3.34.2	11	Paragraph 1	After second sentence insert new sentence "The District shall submit PORs for all campuses and grades affected by the grade reconfigurations which are a part of the project."	Clarifies PORs that districts need to be submit with project application
	Partnership Program Rules	3.34.2	11	Paragraph 1	At the end of last sentence add "on or before 2008."	This clarifies time of allowing consideration of single purpose spaces
	Partnership Program Rules	3.34.3	11	Paragraph 1	In first sentence after "Warm, safe and dry" add the word "(systems)"	Clarifies type of project
	Partnership Program Rules	3.34.3	11	Paragraph 1	In the fourth line of the first sentence after "safe and dry" add "system" before the word "projects"	Clarifies type of project.
	Partnership Program Rules	4.02	13	2nd Paragraph	Last sentence - after the words "The district will have to" Strike "choose" and add the words "submit a POR showing"	Clarifies POR requirement
	Partnership Program Rules	4.02	13	5th Paragraph	Add the words "PORs and" after the word "approved"	Clarifies submission requirements
	Partnership Program Rules	4.02.1	13	Paragraph 1	Add the words "and District submitted PORs" after the words "schematic drawings"	Clarifies submission process
	Partnership Program Rules	4.05.2	14	Paragraph (ii)	After the words "tax measures" insert period and strike the rest of the sentence.	Clarifies resolution requirements
	Partnership Program Rules	4.05.2	14	Paragraph (ii)	After the period after "tax measures." Ad sentence "If, as of the date of application, the school district has already obtained elector approval of the bond or tax measure, the resolution shall identify the date of the election at which approval was obtained.	Clarifies resolution requirements.
	Partnership Program Rules	4.05.2	14	Paragraph (iii)	Add "(iii) If the board of directors of the school districts intends to apply other local resources to pay the school district's share of the financial participation in the new construction project, and does not intend to seek elector approval of a bond or tax measure, the resolution shall specify the approximate date the board intends to apply the other local resources."	Clarifies resolution requirements.
	Partnership Program Rules	4.05.2	14	Paragraph (iv)	New paragraph (iv) add "If the resolution does not identify an approximate date for elector approval or application of other local resources, the submission shall be denied by the Division."	Clarifies resolution requirements
	Partnership Program Rules	4.05.9	15	Add new Paragraph	Add "District submitted PORs in accordance with the requirements of Section 3.34 of these rules."	Clarifies POR submission
	Partnership Program Rules	4.05.9 (i)	15	Add new Paragraph	Add (i) On new campus to compute suitability	Clarifies POR submission

**Proposed Rule Change List  
August 29, 2013**

NUMBER	SECTION	CHAPTER	PAGE	Paragraph	ITEM	PROPOSED CORRECTION
	Partnership Program Rules	4.05.9 (ii)	15	Add new Paragraph	Add (ii) On an existing campus to compute suitability	Clarifies POR submission
	Partnership Program Rules	4.05.9 (iii)	15	Add new Paragraph	Add "(iii) On other existing campuses to compute excess suitability"	Clarifies POR submission
	Partnership Program Rules	4.06	15	Paragraph 1	After "Appendix" strike "B" and replace with "A"	Corrects appendix reference
	Partnership Program Rules	4.07	16	Paragraph 1	After "Appendix" strike "C" and replace with "B"	Corrects appendix reference
	Partnership Program Rules	5.01.6	18	New Paragraph and Section	Add sentence 5.01.6 "In evaluating a school district's application for state financial participation in a new construction project, the Division may resolve any internal inconsistency in or conflict among the application components and supporting documentation by giving precedence to the application components in the following order:"	Sets sequence of document priority
	Partnership Program Rules	5.01.6 (i)	18	New Paragraph	Add (i) "The resolution adopted by the board of directors of the school district;"	Sets sequence of document priority
	Partnership Program Rules	5.01.6 (ii)	18	New Paragraph	Add (ii) "The narrative application contents submitted electronically through the Master Plan Web Tool;"	Sets sequence of document priority
	Partnership Program Rules	5.01.6 (iii)	18	New Paragraph	Add (iii) "Schematic drawings; and"	Sets sequence of document priority
	Partnership Program Rules	5.01.6 (iv)	18	New Paragraph	Add (iv) "Other supporting documents submitted with the application."	Sets sequence of document priority
	Partnership Program Rules	5.05.1	20	Paragraph (ii)	Beginning of sentence strike word "No" and make "warm" upper case "W" to begin sentence	Changes "warm, safe and dry systems" projects to third priority
	Partnership Program Rules	5.05.1	20	Paragraph (ii)	End of sentence after "Project Funding Cycle" add "in a ranking of third priority"	Clarifies ranking order after 2019.
	Partnership Program Rules	5.05.2	20	Paragraph 1	Add at beginning of sentence "For the 2015-2017 and 2017-2019 project funding cycles,"	Clarifies the timeline of the second order of ranking
	Partnership Program Rules	5.05.2	21	Paragraph 3	After second sentence add third sentence "After the 2017-2019 project funding cycle, projects in this section shall be entitled to receive state partnership assistance in a ranking of first priority order."	Clarifies ranking priority
	Partnership Program Rules	5.05.3	21	Paragraph 1	Beginning of paragraph add "For the 2015-2017 and 2017-2019 project funding cycles,"	Clarifies timeline for rankings
	Partnership Program Rules	5.05.3	22	Paragraph 7	Add 7th paragraph "After the 2017-2019 project funding cycle, projects in this section shall be entitled to receive state partnership assistance in a ranking of second priority order."	Clarifies ranking order after 2019.
	Partnership Program Rules	5.06	24	Paragraph 1	After "Appendix" strike "D" and replace with "C"	Corrects appendix reference

**Proposed Rule Change List  
August 29, 2013**

NUMBER	SECTION	CHAPTER	PAGE	Paragraph	ITEM	PROPOSED CORRECTION
	Partnership Program Rules	5.07	24	New Paragraph	Add 5.07 "In accordance with Ark. Code Ann. § 6-21-114(d) and the Commission's Rules Governing Property Insurance Requirements every academic facility must be insured for at least 90% of replacement cost to be eligible for state financial participation. If, as of the date of application or at any point thereafter, an academic facility involved in a project is not sufficiently insured as required, as indicated in the district's current Statement of Values, the application shall be denied by the Division and any state financial participation shall cease."	Clarifies insurance requirement
	Partnership Program Rules	6.02 (iii)	25	Paragraph (iii)	After the word "ranked" strike the words " with other" and add "after all of the approved"	Clarifies ranking and funding
	Partnership Program Rules	7.02 (i)	26	Paragraph (i)	Strike the 3rd sentence "Schematic drawings should .....of the entire project."	Requirement moved to 3.30 of these rules
	Partnership Program Rules	7.02 (i)	26	Paragraph (i)	Strike the 4th sentence "For "warm, safe and dry" projects, the major system components and their location should be identified."	Requirement moved to 3.30 of these rules